

CPR - DECLARATION of PERFORMANCE

N° AT0810CPR (Conformity EU 305/2011)

1. Unique identification code of the product type:

AV411ALE

Advantronic Systems SL

2. Type, batch or serial number or any other element allowing identification of the construction product as required under article 11(4) of the CPR:

AV411ALE – Analogue Addressable Type A Outdoor Manual Call Point with short circuit isolator WATERPROOF

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use in compatible fire detection and alarm system

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under article 11(5):

ADVANTRONIC SYSTEMS SL
C/ Yunque, 9 Nave B1
28760 – Tres Cantos – Madrid - Spain
advantronic@advantronic.es www.advantronic.es

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by harmonized standard:

EN 54-11: 2001 + A1:2005
EN 54-17: 2005

Bre Global Ireland, N.B. No. 2831, performed the necessary initial inspection of the manufacturing plant and the factory production control together with ongoing continuous

surveillance and issued the certificate confirming constancy of the conformity of the factory production control

Product number
AV411ALE

CPR Number
2831-CPR-F4474

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

N/A

9. Declared performance:

ESSENTIAL CHARACTERISTICS	CLOSE APPLICABLE	PERFORMANCE	HARMONISED STANDARD
Nominal activation conditions/ sensitivity and performance under fire condition	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2, 5.3	PASS	EN 54-11:2001 + A1:2005
Operational reliability	4.2, 4.3.1, 4.5, 4.6, 4.7.2, 4.7.3, 4.7.5, 4.8, 5.4, 5.5	PASS	
Durability of operational reliability, temperature resistance	5.7, 5.9	PASS	
Durability of operational reliability, vibration resistance	5.14 to 5.17	PASS	
Durability of operational reliability, humidity resistance	5.10, 5.12	PASS	
Durability of operational reliability, corrosion resistance	5.11, 5.13	PASS	
Durability of operational reliability, electrical stability	5.6, 5.18	PASS	

ESSENTIAL CHARACTERISTICS	CLOSE APPLICABLE	PERFORMANCE	HARMONISED STANDARD
Performance parameters under fire conditions	5.2	PASS	EN 54-17:2005
Operational reliability	4	PASS	
Durability of operational reliability, temperature resistance	5.4, 5.5	PASS	
Durability of operational reliability, vibration resistance	5.9 to 5.12	PASS	
Durability of operational reliability, humidity resistance	5.6, 5.7	PASS	

Durability of operational reliability, corrosion resistance	5.8	PASS
Durability of operational reliability, electrical stability	5.3, 5.13	PASS

10. The performance of the products identified in points 1 and 2 are in conformity with the declared performance in the point 9. This declaration is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Andrés Martínez – General Manager – Advantronic Systems SL, Tres Cantos – Madrid - Spain

Tres Cantos, 10 October 2020

Andrés Martínez
General Manager